


FIRE SAFETY CERTIFICATE

Certified that the Modern School located at Barakhamba Road, New Delhi comprises of Three blocks, Platinum Jubilee Block & S.S. Block- Ground + 02 Upper floor each and Main Building- Ground + 01 Upper floor & 01 store room at terrace owned/occupied by Modern School was granted NOC by this department vide letter No. F6/DFS/MS/School/2018/NDZ/749 dated 20/04/2018. The premises was re-inspected by the officer concerned of this department on 12-07-2021 in the presence of Sh. Rishi Pandya, Maintenance, in charge and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from ~~19/7/2021~~ 2021 for a period of three years subject to compliance of the conditions mentioned below:

Issued on 19/7/21..... at New Delhi by.



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal,
Modern School at Barakhamba, Road, New Delhi
2. Director of Education,
Govt. of NCT of Delhi,
Old Secretariat, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".


Principal
MODERN SCHOOL
Barakhamba Road,
New Delhi-110 001